



System 200 – Performance Specification

06.10.2023

Project Name:

xxx
Architect:
xxx
Location:
xxx
Building Type:
xxx

Glazing Specification:

6.4 Laminated Inner/18 Cavity/4mm Annealed Outer

Composite Windows

Windows, curtain walling and other glazed areas are to be a unitised composite aluminium/wood system with a uniform appearance, ie fixed lights have same modular sight-lines as opening lights.

The system must be a fully ventilated and drained system with concealed drain-channels, thermally broken and prefabricated.

The system must have an internal structural frame of Scandinavian Pinewood (Pinus Sylvestris), and an external thermally broken aluminium sash alloy AIMgS0,5.

Glazing

The sealed glass unit must be internally dry-glazed argon filled with EPDM gaskets and the glass rebate must be formed of aluminium.

Aluminium

54mm wide T-shaped thermally broken aluminium extrusion alloy EN AW-6060 or EN AW-6063.

Ironmongery

Friction stays, sliding tracks, hinges and handles must be sourced from one single manufacturer and/or must have been developed and engineered specifically with the proposed window system in mind.

Opening handles are to be single handles incorporating a multipoint locking mechanism fully concealed within the sash with only one handle permitted per window in a brushed anodized finish.

Finishes

The external aluminium sash must be polyester powdercoated in compliance with BS 6496, BS 6497, GSB and DIN 50939, in RAL colour [] to gloss level 30% and a primary coating thickness of between 60-120 μ m.

The internal structural frames mullions and transoms of Scandinavian Pinewood must be Flow-coat-treated

preservative treated with fungicides and have a further two coat factory pre-finish with an environmentally friendly (solvent free) 100% Acryl emulsion/water-based surface treatment.

The coating is to have a dry paint thickness of between 60-100 μ m and a colourless finish to gloss level 25 (silk matt) or painted in one of a range of colours RAL [].

Performance

The proposed TEROCO/VELFAC window system must have an expected lifespan of 40 years with regular maintenance.

The TEROCO/VELFAC window system must meet the air permeability requirements of test pressure class 600PA given in EN1026 (BS 6375 part 1), and no deformation or damage must be recorded at an applied wind pressure of 1800PA using test method EN 12211 (BS 6375 part 1).

The window system must meet the weather tightness requirements of test pressure class 300 given in BS 6375 part 1, and the window system must be tested to meet the requirements of BS 6375 part 2.

Strengths

The TEROCO/VELFAC window system, glazing and fixings must be designed with full consideration to the anticipated imposed loads based upon the following data.

Window loads in accordance with CP3: Chapter 5: Part 2: (1972) for a basic wind speed, V=[] in category [].

Thermal Transmittance

The thermal transmittance (U value) for the window system and glazing shall not exceed: Window U-value DGU = 1.1 - 1.58 W/m2 K, Window U-value TGU = .8 - 1.0 W/m2 K, spandrel panels U-value = as per requirements glass U-value = [1.1] W/m2 K.

This is based on a TEROCO/VELFAC window 1230 x 1480mm as specified in BS EN ISO 12567-1.

Interface details

TEROCO RP200 render profile to be used in conjunction with the VELFAC V200 window where indicated. 8-15mm Shadow gaps to be shown externally required for ventilation & system operation

Resistance to Forced Entry - SBD

The TEROCO/VELFAC system must pass the PAS 24 (BS7950) tests for Secured By Design.

Supplier

TEROCO Windows & Door Unit B1, Riverview Business Park, Nangor Road, D12 T227 Unit 16, Eastgate Drive, Little Island, Cork, T45 T623 Tel: +353 1 403 9999 Web: www.TEROCO.ie Email: tenders@TEROCO.ie